

Titre: Large-signal modeling of three-phase dual active bridge converters
Title: for electromagnetic transient analysis in DC grids

Auteurs: Maxime Berger, Ilhan Kocar, Handy Fortin-Blanchette, & Carl
Authors: Lavertu

Date: 2019

Type: Article de revue / Article

Référence: Berger, M., Kocar, I., Fortin-Blanchette, H., & Lavertu, C. (2019). Large-signal
Citation: modeling of three-phase dual active bridge converters for electromagnetic
transient analysis in DC grids. Journal of Modern Power Systems and Clean
Energy, 7 (6), 1684-1696. <https://doi.org/10.1007/s40565-019-0531-8>

Document en libre accès dans PolyPublie

Open Access document in PolyPublie

URL de PolyPublie:
PolyPublie URL: <https://publications.polymtl.ca/4783/>

Version: Version officielle de l'éditeur / Published version
Révisé par les pairs / Refereed

Conditions d'utilisation:
Terms of Use: CC BY

Document publié chez l'éditeur officiel

Document issued by the official publisher

Titre de la revue: Journal of Modern Power Systems and Clean Energy (vol. 7, no. 6)
Journal Title:

Maison d'édition: Springer Nature
Publisher:

URL officiel: <https://doi.org/10.1007/s40565-019-0531-8>
Official URL:

Mention légale:
Legal notice:



Large-signal modeling of three-phase dual active bridge converters for electromagnetic transient analysis in DC grids



Maxime BERGER^{1,2}, Ilhan KOCAR¹ , Handy FORTIN-BLANCHETTE³,
Carl LAVERTU²

Abstract The three-phase dual active bridge (3p-DAB) converter is widely considered in next-generation DC grid applications. As for traditional AC grids, the successful integration of power electronic converters in DC grids requires accurate time-domain system-level studies. As demonstrated in the existing literature, the development and efficient implementation of large-signal models of 3p-DAB converters are not trivial. In this paper, a generalized average model is developed, which enables system-level simulation of DC grids with 3p-DAB converters in electromagnetic transient type (EMT-type) programs. The proposed model is rigorously compared with alternative modeling techniques: ideal-model, switching-function and state-space averaging. It is concluded that the generalized average model provides an optimal solution when accuracy of transient response, reduction in computation time, and wideband response factors are considered.

Keywords Three-phase dual active bridge (3p-DAB), Generalized averaging, Large-signal analysis, Electromagnetic transient, DC–DC conversion

1 Introduction

There is a surge of interest in academic and industrial research on DC grids mainly due to their well-known advantages over AC grids in a number of applications [1, 2]. DC distributions are being developed for applications such as transportation [3, 4], commercial and industrial buildings [5, 6], data centers [7], generating stations [8], and integration of distributed resources [9].

Power electronics interfaces play a key role in DC grids [10]. The three-phase dual active bridge (3p-DAB) DC–DC converter topology is widely considered to meet various requirements such as capability of bidirectional power flow, galvanic isolation, high efficiency and high power density [11–13]. The 3p-DAB also allows the use of different winding connections among which the Y– Δ type connection has been shown to provide increased performance [14].

Small-signal frequency-domain modeling of converters is important in controller and filter design as well as the first stability assessments [15]. As for traditional AC grids, the integration of power electronics in DC grids also requires time-domain system-level studies such as voltage regulation performance with load variations, transient stability, and protection coordination [16–19]. Since the behavior of a converter depends on both its topology and controller, the closed-loop modeling of converters is necessary for system-level studies [20].

Each topology has its own particularities which should be considered in the development process of simulation

CrossCheck date: 28 February 2019

Received: 15 November 2018 / Accepted: 28 February 2019 /
Published online: 17 May 2019

© The Author(s) 2019

✉ Ilhan KOCAR
ilhan.kocar@polymtl.ca

Maxime BERGER
maxime.berger@polymtl.ca

Handy FORTIN-BLANCHETTE
handy.fortin-blanchette@etsmtl.ca

Carl LAVERTU
carl.lavertu@rail.bombardier.com

¹ Polytechnique Montreal, Montreal, Canada

² Bombardier Transportation, St-Bruno-de-Montarville, Canada

³ Ecole de Technologie Supérieure, Montreal, Canada

models. Large-signal modeling of 3p-DAB converters is not trivial because of its DC-AC-DC structure, three-phase transformer connections and higher number of switches compared to other isolated bidirectional DC-DC converter topologies [21]. The methodology presented in [22] is the first attempt to reduce the computation time for system-level studies with 3p-DAB in electromagnetic transient type (EMT-type) programs. A discretized switching function (SWF) model in the $\alpha\beta$ frame is implemented. It reduces the number of electrical nodes while preserving the switching effect. However, it still requires time steps in the range of $1/1000^{\text{th}}$ of the switching period to maintain numerical stability. The reduction in the computation time compared to the ideal model approach is also not shown.

The ideal model approach is in fact well-known for the analysis of 3p-DAB converters and other topologies because its implementation using ideal switches is straightforward in circuit simulation tools. Ideal model is a good reference for model validation [19, 23]. However, because the circuit topology is time-variant, and the switching effect is modeled, the computation time is demanding for system-level studies.

The SWF method [24] is proposed as an alternative methodology to ideal model in which the converter circuit is replaced by controlled voltage and current sources. Since the circuit topology is time-invariant, the SWF method reduces the computation time [17]. However, since it keeps the switching effect, small time steps are still required. Averaged models are well-known for neglecting the switching effect and allowing the use of larger simulation time steps which significantly reduce the computation time [25, 26].

In this paper, a generalized averaging model (GAM) of the Y- Δ type 3p-DAB converter is developed, implemented and compared with the ideal, SWF [24] and state-space averaging (SSA) [23, 25] methods [23, 25] in electromagnetic transient program (EMTP) [27] as shown in Fig. 1. In Fig. 1, simulation approaches indicated with a star * are compared in this paper. The ideal model is used





Fig. 1 Classification of simulation approaches for time-domain simulation of 3p-DAB converter

as a reference. The main contribution of this paper is to provide a solution to the challenges in developing and implementing a computational efficient and accurate model that enables time-domain system-level simulation of DC grids with 3p-DAB converters. By comparing the performance of the developed GAM with alternative modeling techniques, this paper also provides a complete comprehensive understanding of the advantages and limitations of the GAM approach for the 3p-DAB.


The paper is organized as follows. In Section 2, the operating principles of the 3p-DAB converter are introduced. In Section 3, the development of the GAM model and its generalization to other transformer connections are presented. In Section 4, the performance of the GAM model is analyzed in terms of transient response, computation time and frequency response. A large-scale test system is also implemented to validate the performance of the GAM model for fault current and transient recovery voltage analysis.

2 Operating principle of 3p-DAB converter

The 3p-DAB converter topology is shown in Fig. 2a, where v_i is the input voltage; v_o is the output voltage; i_i is the input current; i_o is the output current; δ is the control phase-shift. Note that, throughout this paper, small letters are used for time-domain variables. Capital letters will be used for steady-state values. The phase-shift is denoted with $\delta = \delta(t)$ and its steady-state value with D .



(a) 3p-DAB topology



(b) Closed-loop control structure in forward operation

Fig. 2 3p-DAB converter



The 3p-DAB is composed of two three-phase bridges connected through a three-phase medium-frequency transformer. It is most commonly operated using single phase-shift (SPS) control method with a fixed switching frequency $\omega_s = 2\pi f_s$, and a 180° (or 6-step) modulation scheme [14, 28]. Filter capacitors C_i and C_o are necessary to reduce the voltage ripple at $6f_s$ which is induced by both bridges. Their equivalent series resistances (ESRs), R_{Ci} and R_{Co} , are also included because of their importance in stability analysis [29].

The phase-shift δ between the gating signals applied to the two bridges is the variable used to regulate the voltage of either one of the two ports. For example, in forward operation ($0 \leq \delta \leq \pi/2$), the active power is transferred from the input bridge to the output bridge such that v_o is regulated to reach its reference value V_o^{ref} shown in Fig. 2b. Reverse operation consists in reversing the sign of δ and regulating v_i to reach its reference value V_i^{ref} . In Fig. 2b, G_c is the transfer function of the closed-loop controller and G_f is the transfer function of the output voltage measurement filter. The current source i_{load} is a load perturbation superimposed on the resistive load R and is used to define the converter output impedance $Z_o(s)$ in Section 4.5.

In steady state, the relationships between the input and output voltages for the Y- Δ type 3p-DAB converter are given as follows.

$$V_o = \begin{cases} \frac{mRD}{\omega_s L_s} V_i & 0 < D \leq \frac{\pi}{6} \\ \left(\frac{mR}{\omega_s L_s} \left[\frac{3}{2} \left(D - \frac{D^2}{\pi} \right) - \frac{\pi}{24} \right] \right) V_i & \frac{\pi}{6} \leq D \leq \frac{\pi}{2} \end{cases} \quad (1)$$

where V_i and V_o are the steady state input and output voltages; R is the load resistance; m is the transformer winding ratio ($m = M/\sqrt{3}$); L_s is the total transformer primary referred leakage inductance for which balanced operation is assumed ($L_s = L_A = L_B = L_C$).

3 Generalized averaging model

The GAM method, also known as dynamic phasor [26], is a recognized methodology for the analysis of power electronics converters [30–34]. The idea is to decompose the converter state variables and its switching functions using a k th coefficient Fourier series. For the 3p-DAB, it is proposed here to use only the index $k = 0$ for the DC voltages, and the index $k = \pm 1$ for both the transformer AC currents and switching function components at the switching frequency ω_s . Higher harmonics are not considered because the three-phase structure leads to a next

harmonic at $k = 6$ which can generally be neglected in system-level studies. This will be shown in Section 4.1.

Seen from the DC grids, the GAM method leads to the equivalent index-0 model shown in Fig. 3. In Fig. 3, diodes D_i and D_o are used to model the clamping effect of the three-phase bridge freewheeling diodes on negative voltage at the DC ports. Their importance is showed through an example in Section 4.3. The index-0 model is governed by a system of equations which is function of the index-1 model. The index-1 model includes the AC dynamic of both the transformer currents and the switching functions shown in Fig. 4.

The large-signal model of the 3p-DAB converter is given here using the following state-space notation:

$$\frac{d}{dt} \langle \mathbf{x} \rangle = \mathbf{A} \langle \mathbf{x} \rangle + \mathbf{B} \langle \mathbf{u} \rangle \quad (2)$$

$$\langle \mathbf{y} \rangle = \mathbf{C} \langle \mathbf{x} \rangle + \mathbf{D} \langle \mathbf{u} \rangle \quad (3)$$

where $\langle \mathbf{x} \rangle$, $\langle \mathbf{u} \rangle$, $\langle \mathbf{y} \rangle$ are the vectors of averaged state-variables, inputs and outputs respectively:

$$\langle \mathbf{x} \rangle = [\langle i_A \rangle_1^R \quad \langle i_A \rangle_1^I \quad \langle i_B \rangle_1^R \quad \langle i_B \rangle_1^I \quad \langle i_C \rangle_1^R \quad \langle i_C \rangle_1^I]^T \quad (4)$$

$$\langle \mathbf{u} \rangle = [\langle v_i \rangle_0 \quad \langle v_o \rangle_0]^T \quad (5)$$

$$\langle \mathbf{y} \rangle = [\langle i_i \rangle_0 \quad \langle i_o \rangle_0]^T \quad (6)$$

where the superscripts R and I denote the real and imaginary components of the averaged state-variables. The definition of the system matrices \mathbf{A} , \mathbf{B} , \mathbf{C} and \mathbf{D} which are time-dependent, requires to first write the index-0 input and output currents in terms of both the transformer primary currents, and the input and output bridge switching functions. The switching functions for the input bridge s_1 , s_3 , and s_5 , and the output bridge s'_1 , s'_3 , s'_5 are defined by the gating signals coming from the output of the modulator as shown in Fig. 4. For phase B, the switching functions s_3 and s'_3 are -120° phase-shifted from phase A. For phase C, the switching functions s_5 and s'_5 are $+120^\circ$ phase-shifted from phase A.

The input current is given by:

$$i_i = s_1 i_A + s_3 i_B + s_5 i_C \quad (7)$$

While (7) is valid for any transformer connection, the winding connection is included along with its ratio m in the output current equation. For the Y- Δ type (-30°) connection, it leads to:




Fig. 3 Equivalent GAM of 3p-DAB seen from DC grids




Fig. 4 Switching functions s_1 and s_1' of phase A for Y-Δ type (-30°) transformer

$$i_o = m[(s_1' - s_3')i_A + (s_3' - s_5')i_B + (s_5' - s_1')i_C] \quad (8)$$

where s_1' , s_3' , s_5' are dependent on the instantaneous value of the control phase-shift $\delta = \delta(t)$. To evaluate (7) and (8), the following primary transformer current equations should be solved:

$$\frac{di_A}{dt} = (1/L_A)[((2s_1 - s_3 - s_5)/3)v_i - m(s_1' - s_3')v_o] \quad (9)$$

$$\frac{di_B}{dt} = (1/L_B)[((2s_3 - s_1 - s_5)/3)v_i - m(s_3' - s_5')v_o] \quad (10)$$

$$\frac{di_C}{dt} = (1/L_C)[((2s_5 - s_1 - s_3)/3)v_i - m(s_5' - s_1')v_o] \quad (11)$$

Equations (7)–(11) are averaged using Fourier series properties [26, 35, 36]. The resulting system of equations defined by (2)–(6) and (12)–(18) is implemented in EMTP by the control blocks, and solved using [37]. The calculated values of the input current $\langle i_i \rangle_0$ and the output current $\langle i_o \rangle_0$ are used to control the current sources of Fig. 3. The system matrices are given by:

$$\left\{ \begin{array}{l} \mathbf{A} = \begin{bmatrix} 0 & \omega_s & 0 & 0 & 0 & 0 \\ -\omega_s & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & \omega_s & 0 & 0 \\ 0 & 0 & -\omega_s & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 & \omega_s \\ 0 & 0 & 0 & 0 & -\omega_s & 0 \end{bmatrix} \\ \mathbf{B} = \begin{bmatrix} B_{11} & B_{12} \\ B_{21} & B_{22} \\ B_{31} & B_{32} \\ B_{41} & B_{42} \\ B_{51} & B_{52} \\ B_{61} & B_{62} \end{bmatrix} \\ \mathbf{C} = \begin{bmatrix} C_{11} & C_{12} & C_{13} & C_{14} & C_{15} & C_{16} \\ C_{21} & C_{22} & C_{23} & C_{24} & C_{25} & C_{26} \end{bmatrix} \\ \mathbf{D} = \begin{bmatrix} 0 & 0 \\ 0 & 0 \end{bmatrix} \end{array} \right. \quad (12)$$

with

$$\left\{ \begin{array}{l} B_{12} = \frac{m}{L_A} (\langle s_3' \rangle_1^R - \langle s_1' \rangle_1^R) \\ B_{22} = \frac{m}{L_A} (\langle s_3' \rangle_1^I - \langle s_1' \rangle_1^I) \\ B_{32} = \frac{m}{L_B} (\langle s_5' \rangle_1^R - \langle s_3' \rangle_1^R) \\ B_{42} = \frac{m}{L_B} (\langle s_5' \rangle_1^I - \langle s_3' \rangle_1^I) \\ B_{52} = \frac{m}{L_C} (\langle s_1' \rangle_1^R - \langle s_5' \rangle_1^R) \\ B_{62} = \frac{m}{L_C} (\langle s_1' \rangle_1^I - \langle s_5' \rangle_1^I) \end{array} \right. \quad (13)$$

$$\left\{ \begin{array}{l} B_{11} = \frac{1}{3L_A} [2\langle s_1 \rangle_1^R - \langle s_3 \rangle_1^R - \langle s_5 \rangle_1^R] \\ B_{21} = \frac{1}{3L_A} [2\langle s_1 \rangle_1^I - \langle s_3 \rangle_1^I - \langle s_5 \rangle_1^I] \\ B_{31} = \frac{1}{3L_B} [2\langle s_3 \rangle_1^R - \langle s_1 \rangle_1^R - \langle s_5 \rangle_1^R] \\ B_{41} = \frac{1}{3L_B} [2\langle s_3 \rangle_1^I - \langle s_1 \rangle_1^I - \langle s_5 \rangle_1^I] \\ B_{51} = \frac{1}{3L_C} [2\langle s_5 \rangle_1^R - \langle s_1 \rangle_1^R - \langle s_3 \rangle_1^R] \\ B_{61} = \frac{1}{3L_C} [2\langle s_5 \rangle_1^I - \langle s_1 \rangle_1^I - \langle s_3 \rangle_1^I] \end{array} \right. \quad (14)$$

$$\left\{ \begin{array}{l} C_{21} = 2m(\langle s_1' \rangle_1^R - \langle s_3' \rangle_1^R) \\ C_{22} = 2m(\langle s_1' \rangle_1^I - \langle s_3' \rangle_1^I) \\ C_{23} = 2m(\langle s_3' \rangle_1^R - \langle s_5' \rangle_1^R) \\ C_{24} = 2m(\langle s_3' \rangle_1^I - \langle s_5' \rangle_1^I) \\ C_{25} = 2m(\langle s_5' \rangle_1^R - \langle s_1' \rangle_1^R) \\ C_{26} = 2m(\langle s_5' \rangle_1^I - \langle s_1' \rangle_1^I) \end{array} \right. \quad (15)$$

$$\left\{ \begin{array}{l} C_{11} = 2\langle s_1 \rangle_1^R \\ C_{12} = 2\langle s_1 \rangle_1^I \\ C_{13} = 2\langle s_3 \rangle_1^R \\ C_{14} = 2\langle s_3 \rangle_1^I \\ C_{15} = 2\langle s_5 \rangle_1^R \\ C_{16} = 2\langle s_5 \rangle_1^I \end{array} \right. \quad (16)$$

For the input bridge, the averaged switching functions are constant because they do not depend on the control phase-shift. They are given by:

$$\begin{cases} \langle s_1 \rangle_1 = \frac{1}{\pi} e^{-j\frac{\pi}{2}} \\ \langle s_3 \rangle_1 = \frac{1}{\pi} e^{j\frac{\pi}{6}} \\ \langle s_5 \rangle_1 = \frac{1}{\pi} e^{j\frac{5\pi}{6}} \end{cases} \quad (17)$$

For the output bridge, they depend on the instantaneous value of the control phase-shift $\delta = \delta(t)$ and are referenced with respect to the input bridge:

$$\begin{cases} \langle s'_1 \rangle_1 = \langle s_1 \rangle_1 e^{-j(\frac{\pi}{6} + \delta)} \\ \langle s'_5 \rangle_1 = \langle s_5 \rangle_1 e^{-j(\frac{\pi}{6} + \delta)} \\ \langle s'_3 \rangle_1 = \langle s_3 \rangle_1 e^{-j(\frac{\pi}{6} + \delta)} \end{cases} \quad (18)$$

4 Performance comparison

4.1 Closed-loop time-domain transient response

The transient response of the GAM model is first compared with equivalent closed-loop ideal, SWF and SSA models in EMT. The converter parameters are given in Table 1.

Large-signal step function perturbations are applied and the resulting output voltage v_o is shown in Figs. 5, 6, 7 and 8. The results are analyzed in Section 4.6. In Fig. 5, the integration time step is $\Delta t = 0.01 \mu\text{s}$ for the reference (Ref.) and SWF models, and $\Delta t = 0.1 \mu\text{s}$ for the GAM and SSA models. In Fig. 6, it shows the converter output voltage when the input voltage is stepped from 800 V to 400 V. It is observed that the SWF and GAM models consider the transient oscillations at the switching frequency f_s . In Fig. 7, converter output voltage when the load is stepped from high-load condition ($R = 0.94 \Omega$) to no-load condition. It is concluded that all the models consider the transient oscillations at the cross-over frequency f_{om} . In Fig. 8, it is shown that only the SWF model includes the ripple at $6f_s$. The component at $6f_s$ is negligible in large-




Fig. 5 Simulation results for complete simulation run




Fig. 6 Zoom #1 on simulation results

signal studies because the ripple at $6f_s$ is generally significantly attenuated by C_o .

4.2 Simulation timing analysis

When performing system-level studies, the simulation time step Δt is generally selected based on the frequency spectra of the targeted power system studies. In the case of many power electronic converters, even for low-frequency phenomena, if the switching effect is modeled, it is

Table 1 3p-DAB converter parameters

Parameters	Symbol	Value
Output voltage set point	V_o^{ref}	37.5 V
Input capacitor	C_i, R_{Ci}	660 nF, 40 mΩ
Output capacitor	C_o, R_{Co}	150 μF, 60 mΩ
Transformer leakage inductance	L_s	420 μH
Transformer ratio	M	16
G_c cross-over frequency (PI-type)	f_{om}	1.5 kHz
G_c phase-margin (PI-type)	φ_m	45°
Low-pass filter G_f (2nd order Butterworth)	f_o	5 kHz




Fig. 7 Zoom #2 on simulation results





Fig. 8 Zoom #3 on simulation results

necessary to reduce the time step Δt to typically $1/100^{\text{th}}$ of the switching period $1/f_s$ (rule of thumb). In the case of the 3p-DAB, since the ripple is at $6f_s$, it requires having a time step smaller than around $1/600^{\text{th}}$ of the switching period. This problem has been highlighted in [22] for the specific case of the 3p-DAB converter.

Since the computation time t_{cpu} highly depends on the integration time step Δt , multiple simulation runs as in Fig. 5 have been performed to thoroughly compare the models. The results are shown in Fig. 9 and are further analyzed in Section 4.6. An Intel® Core™ processor i7-4700HQ (2.4 GHz) with 12 GB of RAM, and EMTP-RV software version 3.4 is used. The simulation time $t_{\text{sim}} = 60$ ms.

4.3 Transient short circuit with multiple 3p-DAB converters

A bolted fault of 20 ms duration is applied at the output of ten 3p-DAB converters connected in parallel through RL devices which model typical converter input filters and output cables. An output VI-characteristic with a 2% droop centered on $V_o^{\text{nom}} = 37.5$ V, and a 10% maximum current

Fig. 9 Computation time for different integration time step Δt for simulation scenario of Fig. 5

limit $I_o^{\text{max}} = 30$ A is implemented to model a common converter fault protection scheme shown in Fig. 10 [4].

The transient short circuit current for each model is shown in Fig. 11. The maximum integration time step obtained in Fig. 9 is used for each model, i.e., $\Delta t = 0.06$ μs for the Ref. model, $\Delta t = 0.1$ μs for the SWF model, and $\Delta t = 1$ μs for the GAM and SSA models. The converter is operated at $V_s = 600$ V and $f_s = 50$ kHz.

A breakdown analysis of the CPU effort is also shown in Fig. 12. The results are also analyzed together in Section 4.6.

Moreover, diodes D_i and D_o are used to model the clamping effect of the 3p-DAB freewheeling diodes on negative voltage at the DC ports. These diodes are always present in practical applications. Their importance on system-level simulation accuracy is shown in Fig. 13 by comparing the ideal model results with the SWF, GAM and SSA model results without D_i and D_o . These diodes are often neglected but their impact may not be negligible as shown experimentally in [38].




Fig. 10 Internal VI-characteristic of each 3p-DAB converter




Fig. 11 Simulation results for a bolted fault at the output of ten 3p-DAB in parallel




Fig. 12 CPU calculation effort of total computation time t_{cpu}

4.4 Validation of GAM for power system transient analysis in a large-scale test system

The effectiveness and accuracy of the GAM model to study large-scale systems are validated through a short circuit test case in which the transient fault current as well as the transient recovery voltages at fault clearing are analyzed.

A single line diagram of the test system is shown in Fig. 14. It is composed of a primary voltage ring bus at 750 V, two intermediate voltage bus at 380 V, and a low voltage ring bus at 110 V. The system is divided into ten identical regions with a total of 20 3p-DAB converters. All the converters are designed with an LC input filter. The parameters of the 3p-DAB converters used in this test case are provided in Table 2. Cables are modeled with equivalent RL circuits (not shown in Fig. 14). Detailed models of battery [4, 39], circuit breaker detection and arcing [4, 40],




Fig. 13 Simulation results for a bolted fault at the output of ten 3p-DAB connected in parallel without D_i and D_o for the SWF, GAM and SSA models

fuse detection and arcing [38], as well as metal oxide varistor (MOV) [38] are used. More details on the mathematical formulation and the implementation of each model can be found in the references provided above.

At $t = 20$ ms, a $1 \text{ m}\Omega$ fault is applied in region 6 of the 110 V bus shown in Fig. 14. The short circuit current and the sequence of events are shown in Fig. 15 while the transient recovery voltage (V5 in Fig. 14) is given in Fig. 16. These results confirm that the developed GAM can be used for accurate grid-level analyses such as fault current evaluation and transient recovery voltage assessment.

The total simulation time t_{sim} is 50 ms. For the reference model, the integration time step Δt is $0.05 \mu\text{s}$, and the total computation time t_{cpu} is 4565 s. This is the largest time step that can be used to maintain numerical stability. For the GAM, the integration time step Δt is increased to $1 \mu\text{s}$ such as the total computation time is significantly reduced to $t_{cpu} = 45$ s.




Fig. 14 Large-scale test system for validation of GAM

Table 2 Summary of 3p-DAB parameters for large-scale test system


Parameter	DABXA*	DABXB*
Nominal input voltage V_i^{nom}	750 V	380 V
Nominal output voltage set-point V_o^{nom}	380 V	110 V
Nominal output power P_o^{nom}	100 kW	10 kW
Maximum output current I_o^{max}	290 A	100 A
Input capacitor C_i	1100 μF	150 μF
Input filter inductor L_i	100 μH	50 μH
Output capacitor C_o	2200 μF	150 μF
Transformer leakage inductance L_s	10 μH	12 μH
Transformer ratio M	1.732	3.45
Switching frequency f_s	20 kHz	50 kHz
G_c cross-over frequency (PI-type) $f_{\phi m}$	1.5 kHz	2.5 kHz
G_c phase-margin (PI-type) ϕ_m	45°	
Low-pass filter G_f (2nd order Butterworth) f_o	5 kHz	

Note: *X = 1, 2, ..., 10


4.5 Closed-loop frequency-domain response

As seen in Fig. 7, the main frequency component of the oscillations in the closed-loop response is close to the cross-over frequency of the designed PI controller, i.e. $f_{\phi m} = 1.5$ kHz.


However, as previously mentioned, for system-level studies, the frequency content is a function of the aimed power system analysis. This means that, instead of being




(a) Fault current for the complete simulation run



(b) Transient fault current at fault application




(c) Transient fault current after DAB6B turn off




(d) Transient fault current during CB5 and CB6 arcing

Fig. 15 Analysis of transient fault current at fault application and during fault clearing

step functions, the large-signal perturbations may contain a large spectrum of frequencies.



(a) Voltage at fault application and fault clearing







(b) Transient recovery voltage during arcing of CB5 and CB6

Fig. 16 Analysis of voltage during fault application and fault clearing

Therefore, the precision of the models at different frequencies is assessed here. For system-level analysis, the input-to-output voltage relationship $G_{vg}^c(s) = (v_o(s)/v_i(s))|_{i_{load}(s)=0}$, the load rejection behavior (also known as back-current gain) $G_{load}^c(s) = (i_i(s)/i_{load}(s))|_{v_i(s)=0}$, the input impedance $Z_{in}^c(s) = (v_i(s)/i_i(s))|_{i_{load}(s)=0}$ and the output impedance $Z_o^c(s) = -(v_o(s)/i_{load}(s))|_{v_i(s)=0}$ are the main closed-loop transfer functions of interest.

The transfer functions G_{vg}^c and G_{load}^c are particularly interesting because they show how perturbations at the input of the converter propagate at the output and vice-versa. The input and output impedances, defined by Z_{in}^c and Z_o^c respectively, are also relevant because, by definition, they show the local reaction of the converter to perturbations at either one of the ports.

The models are validated by applying sine wave perturbations at different frequencies in the simulation models with the parameters shown in Table 1. The perturbations frequency is varied from 100 Hz up to the switching frequency $f_s = 50$ kHz. The magnitude of the output signals is extracted by FFT analysis. The results are shown in Fig. 17 and further analyzed in Section 4.6. In Fig. 17, the converter is operated at the following operating point: $V_i = 600$ V, $V_o = 37.5$ V, $P_o = 1$ kW.

(a) Closed-loop input-to-output voltage gain $|G_{vg}^c(s)|$ (b) Closed-loop load rejection gain $|G_{load}^c(s)|$ (c) Closed-loop input impedance $|Z_{in}^c(s)|$ (d) Closed-loop output impedance $|Z_o^c(s)|$

* Ref.; □ SWF; + GAM; ○ SSA

Fig. 17 Closed-loop frequency response

4.6 Performance analysis

Based on the results obtained in Sections 4.1 to 4.5, the performance of the GAM is now compared with the implemented ideal, SWF and SSA models. The analysis mainly focuses on accuracy, frequency response as well as computational speed. The main outcomes regarding these three criteria are summarized in Table 3. It leads to the conclusion that the proposed GAM offers the best compromise in terms of accuracy, speed and wideband response for system-level analysis. Further details on the implementation of models are summarized in Table 4, while additional justifications are given below.

By first analyzing the time-domain simulation results, it is concluded that all the models accurately represent the averaged dynamic of the converter at the cross-over frequency f_{om} in Fig. 7. As expected, similar to the SWF model, the GAM method also considers the transient component at the switching frequency f_s , but it is not the case with SSA in Fig. 6. The SWF model also considers the output voltage ripple at $6f_s$ (characteristic of the 3p-DAB) while both GAM and SSA neglect this component in Fig. 8. Even if the transient responses of all the models are very similar for step function perturbations in Figs. 6 and 7, it can also be seen from the frequency-domain analysis in Fig. 17 that, unlike the SWF model and the GAM, the SSA model is not accurate to reproduce the

converter behavior for perturbations beyond $1/5$ of f_s . These conclusions are summarized in Table 3.

Furthermore, from Figs. 9 and 11, it is concluded that both GAM and SSA provide a significant increase in computation speed when compared to the reference and SWF models. This is mainly explained by two fundamental differences. The primary reason is the fact that they both allow the use of larger simulation time steps Δt , which significantly increases the computation speed. It is also explained, to a lesser extent, by the reduction in the size of the network main system of equations in Table 4, which, in this case, follows the modified-augmented-nodal analysis (MANA) formulation approach [27, 41].

However, for the same Δt , the benefit in computation speed in Fig. 9 of both the SSA and GAM methods compared to the reference model is much less significant than the reduction in the size of the network main system of equations in Table 4. This is because the size of the network main system of equations cannot be used alone to conclude on the relative simulation speed between models since control system equations are also solved separately from network equations in Table 4 [37, 41]. The computation burden of solving the larger non-linear and coupled set of control equations defined by (2)–(6) and (12)–(18) also explains why, for the same Δt , the computation time is higher with GAM as compared to SSA in Fig. 9.

Finally, it is also worth mentioning that the SWF, GAM and SSA models all lead to a reduced number of solution

Table 3 Comparison summary of 3p-DAB models

Model	Accuracy	Speed	Frequency response (up to)
Ideal-model (Ref.)	1	4	$6f_s$
Switching-function (SWF)	1	3	$6f_s$
Generalized averaging (GAM)	2	2	f_s
State-space averaging (SSA)	3	1	$1/5^{\text{th}}f_s$

Note: Accuracy ranks from 1 (Most accurate) to 3 (Less accurate); speed ranks from 1 (Fastest) to 4 (Slowest)

Table 4 Summary of 3p-DAB model implementation in EMTF

Model	Network Nodes	Size of the network main system of equations	Number of non-zeros	Number of solution points in time-domain (n_{iter})	Control system equations state-space formulation matrices size
Ref.	16*	43*	162*	Eq. (20)	–
SWF	18	29	99	Eq. (19)	–
GAM	6	8	24	Eq. (19)	$A: 6 \times 6$, $B: 6 \times 2$, $C: 2 \times 6$, $D = \mathbf{0}$
SSA	6	8	24	Eq. (19)	$A = \mathbf{0}$, $B = \mathbf{0}$, $C = \mathbf{0}$, $D = 2 \times 2$

Note: * means that each transistor is modeled with an ideal switch in parallel with an ideal free-wheeling diode



points (n_{iter}) in the time-domain as compared to the reference model in Table 4. In fact, for the simplest 3p-DAB model representation, the number of solution points for the SWF, GAM and SSA models is given by

$$n_{\text{iter}} = t_{\text{sim}}/\Delta t \quad (19)$$

while for the reference model, it is fundamentally higher by an additional term $12t_{\text{sim}}f_s$,

$$n_{\text{iter}} = t_{\text{sim}}/\Delta t + 12t_{\text{sim}}f_s \quad (20)$$

This difference is explained by the fact that, at each switching event, EMTP switches from a fixed time step trapezoidal integration method to backward Euler with two half-step ($\Delta t/2$) solutions [42]. This feature helps reduce numerical oscillations when ideal switches are used. It is not required to solve the SWF, GAM, and SSA models because the circuit topology is time-invariant. Furthermore, the simultaneous-switching control algorithm [43], which allows a simultaneous solution of network and control system equations at switching events, also explains why, for the same Δt , the computation time is higher with the reference model.

Finally, the results of the short-circuit test cases in Figs. 11, 15, 16 also show that the developed GAM can effectively be used for accelerating grid-level analyses. The GAM reduces the computation time by a factor of 1/30 in the test case of Fig. 11, while still providing accurate results (error of less than 1% on the peak fault current). As seen in Figs. 15 and 16, the GAM also provides accurate results for typical power system transient analyses such as transient fault current and transient recovery voltage during arcing of circuit breakers. As previously mentioned in Section 4.4, it also provides a significant reduction in computation time for the large-scale test case (factor of 1/100).

5 Conclusion

In this paper, large-signal models of the 3p-DAB converter are developed, analyzed, and implemented in EMTP. It is a key step toward reducing the computation time for time-domain system-level simulation of next-generation DC grids based on the 3p-DAB topology.

Three models are investigated in this paper: SWF, GAM and the SSA. Even if SSA significantly reduces the computation time, it has a limited precision for studying phenomena beyond 1/5 of the converter switching frequency. Because they allow higher time steps, the SWF model and GAM both offer significant reduction in the computation time compared to the ideal-model, while still preserving the converter frequency characteristics up to its switching frequency. However, the maximum time step with the

SWF model is limited by the inclusion of the switching-effect, which still leads to high computation time for system-level studies. Overall, the proposed GAM offers the best compromise in terms of accuracy, speed and wideband response.

Open Access This article is distributed under the terms of the Creative Commons Attribution 4.0 International License (<http://creativecommons.org/licenses/by/4.0/>), which permits unrestricted use, distribution, and reproduction in any medium, provided you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons license, and indicate if changes were made.

References

1. Dragicevic T, Lu X, Vasquez JC et al (2016) DC microgrids Part II: a review of power architectures, applications, and standardization issues. *IEEE Trans Power Electron* 31(5):3528–3549
2. Boroyevich D, Cvetkovic I, Dong D et al (2010) Future electronic power distribution systems a contemplative view. In: *Proceedings of the 12th international conference on optimization of electrical and electronic equipment*, Brasov, Romania, 20–22 May 2010, pp 1369–1380
3. Rosero JA, Ortega JA, Aldabas E et al (2007) Moving towards a more electric aircraft. *IEEE Aerosp Electron Syst Mag* 22(3):3–9
4. Berger M, Lavertu C, Kocar I et al (2016) Proposal of a time-domain platform for short-circuit protection analysis in rapid transit train DC auxiliary systems. *IEEE Trans Ind Appl* 52(6):5295–5304
5. Sannino A, Postiglione G, Bollen MHJ (2003) Feasibility of a DC network for commercial facilities. *IEEE Trans Ind Appl* 39(5):1499–1507
6. Baran ME, Mahajan NR (2003) DC distribution for industrial systems: opportunities and challenges. *IEEE Trans Ind Appl* 39(6):1596–1601
7. Becker DJ, Sonnenberg BJ (2011), DC microgrids in buildings and data centers. In: *Proceedings of the international telecommunications energy conference*, Amsterdam, Netherlands, 9–13 October 2011, 7 pp
8. Berizzi A, Silvestri A, Zaninelli D et al (1996) Short-circuit current calculations for DC systems. *IEEE Trans Ind Appl* 32(5):990–997
9. Robinson J, Jovicic D, Joos G (2010) Analysis and design of an offshore wind farm using a MV DC grid. *IEEE Trans Power Del* 25(4):2164–2173
10. Thandi GS, Zhang R, Xing K et al (1999) Modeling, control and stability analysis of a PEBB based DC DPS. *IEEE Trans Power Del* 14(2):497–505
11. De Doncker RWAA, Divan DM, Kheraluwala MH (1991) A three-phase soft-switched high-power-density DC/DC converter for high-power applications. *IEEE Trans Ind Appl* 27(1):796–805
12. De Din E, Siddique HAB, Cupelli M et al (2018) Voltage control of parallel-connected dual-active bridge converters for shipboard applications. *IEEE J Emerg Sel Topics Power Electron* 6(2):664–673
13. Hou N, Song W, Zhu Y et al (2018) Dynamic and static performance optimization of dual active bridge DC–DC converters. *J Mod Power Syst Clean Energy* 6(3):607–618
14. Baars NH, Everts J, Wijnands CGE et al (2016) Performance evaluation of a three-phase dual active bridge DC–DC converter with different transformer winding configurations. *IEEE Trans Power Electron* 31(10):6814–6823

15. Hamzeh M, Ghafouri M, Karimi H et al (2016) Power oscillations damping in DC microgrids. *IEEE Trans Energy Convers* 31(3):970–980
16. Mohan N, Robbins WP, Undeland TM et al (1994) Simulation of power electronic and motion control systems: an overview. *Proc IEEE* 82(8):1287–1302
17. Jin H (1997) Behavior-mode simulation of power electronic circuits. *IEEE Trans Power Electron* 12(3):443–452
18. Maksimovic D, Stankovic AM, Thottuvelil VJ et al (2001) Modeling and simulation of power electronic converters. *Proc IEEE* 89(6):898–912
19. Chiniforoosh S, Jatskevich J, Yazdani A et al (2010) Definitions and applications of dynamic average models for analysis of power systems. *IEEE Trans Power Del* 25(4):2655–2669
20. Ye Q, Mo R, Li H (2017) Low-frequency resonance suppression of a dual-active-bridge DC/DC converter enabled DC microgrid. *IEEE J Emerg Sel Topics Power Electron* 5(3):982–994
21. Zhao B, Song Q, Liu W et al (2014) Overview of dual-active bridge isolated bidirectional DC–DC converter for high-frequency-link power-conversion system. *IEEE Trans Power Electron* 29(8):4091–4106
22. Uhl R, Arasteh A, Monti A et al (2017) Nodal-reduced modeling of three-phase dual-active bridge converters for EMTP-type simulations. In: *Proceedings of the 26th international symposium on industrial electronics*, Edinburgh, Scotland, 19–21 June 2017, pp 787–792
23. Engel SP, Soltau N, Stage H et al (2013) Dynamic and balanced control of three-phase high-power dual-active bridge DC–DC converters in DC-grid applications. *IEEE Trans Power Electron* 28(4):1880–1889
24. Salazar L, Joos G (1994) PSPICE simulation of three-phase inverters by means of switching functions. *IEEE Trans Power Electron* 9(1):35–42
25. Middlebrook RD, Cuk S (1976) A general unified approach to modelling switching-converter power stages. In: *Proceedings of the power electronics specialists conference*, Cleveland, USA, 8–10 June 1976, pp 18–34
26. Sanders S, Noworolski J, Liu X et al (1991) Generalized averaging method for power conversion circuits. *IEEE Trans Power Electron* 6(2):251–259
27. Mahseredjian J, Denetiere S, Dube L et al (2007) On a new approach for the simulation of transients in power systems. *Electr Power Syst Res* 77(11):1514–1520
28. Berger M, Kocar I, Fortin-Blanchette H et al (2018) Hybrid average modeling of three-phase dual active bridge converters for stability analysis. *IEEE Trans Power Del* 33(4):2020–2029
29. Shi L, Lei W, Li Z et al (2018) Stability analysis of digitally controlled dual active bridge converter. *J Mod Power Syst Clean Energy* 6(2):375–383
30. Chandrasekar S, Gokaraju R (2015) Dynamic phasor modeling of type 3 DFIG wind generators (including SSCI phenomenon) for short-circuit calculations. *IEEE Trans Power Del* 30(2):887–897
31. Liu C, Bose A, Tian P (2014) Modeling and analysis of HVDC converter by three-phase dynamic phasor. *IEEE Trans Power Del* 29(1):3–12
32. Kish GJ, Lehn PW (2018) Linearized DC-MMC models for control design accounting for multifrequency power transfer mechanisms. *IEEE Trans Power Del* 33(1):271–281
33. Huang Y, Dong L, Ebrahimi S et al (2017) Dynamic phasor modeling of line-commutated rectifiers with harmonics using analytical and parametric approaches. *IEEE Trans Energy Convers* 32(2):534–547
34. Emadi A (2004) Modeling and analysis of multiconverter DC power electronic systems using the generalized state-space averaging method. *IEEE Trans Ind Electron* 51(3):661–668
35. Qin H, Kimball JW (2012) Generalized average modeling of dual active bridge DC–DC converter. *IEEE Trans Power Electron* 27(4):2078–2084
36. Li Z, Wang Y, Shi L (2017) Generalized averaging modeling and control strategy for three-phase dual-active-bridge DC–DC converters with three control variables. In: *Proceedings of 32nd annual IEEE applied power electronics conference and exposition*, Tampa, USA, 26–30 March 2017, pp 1078–1084
37. Mahseredjian J, Dube L, Zou M et al (2006) Simultaneous solution of control system equations in EMTP. *IEEE Trans Power Syst* 21(1):117–124
38. Berger M, Grave JM, Lavertu C et al (2018) Modeling, simulation, and testing of switching surge transients in rapid transit vehicles dc power systems. *IEEE Trans Ind Appl* 54(1):822–831
39. Tremblay O, Dessaint LA (2009) Experimental validation of a battery dynamic model for EV applications. *J World Electr Veh* 3(1):1–10
40. Wu H, Yuan L, Sun L et al (2015) Modeling of current-limiting circuit breakers for the calculation of short-circuit current. *IEEE Trans Power Del* 30(2):652–656
41. Mahseredjian J, Dinavahi V, Martinez JA (2009) Simulation tools for electromagnetic transients in power systems: Overview and challenges. *IEEE Trans Power Del* 24(3):1657–1669
42. Marti J, Lin J (1989) Suppression of numerical oscillations in the EMTP. *IEEE Trans Power Syst* 4(2):739–747
43. Zou M, Mahseredjian J, Joos G et al (2006) Interpolation and reinitialization in time-domain simulation of power electronic circuits. *Electr Power Syst Res* 76(8):688–694

Maxime BERGER received the B.Eng. degree from the Université du Québec à Rimouski, Rimouski, Canada, in 2014, and the M.A.Sc. degree from Polytechnique Montréal, Montréal, Canada, in 2016, where he is currently working toward the Ph.D. degree in electrical engineering. Since 2012, he is with Bombardier Transportation, St.-Bruno, where he has been working in the Systems Integration Department. His research interests include power electronics, protection, and the simulation and analysis of power systems transients. His research is supported by Bombardier Transportation, the Fonds de Recherche du Québec-Nature et Technologies, and the Natural Sciences and Engineering Research Council of Canada through the Industrial Innovation Scholarship Program.

Ilhan KOCAR received the B.Sc. and M.Sc. degrees in electrical and electronics engineering from Orta Dogu Teknik Universitesi (ODTU/METU), Ankara, Turkey, in 1998 and 2003, respectively, and the Ph.D. degree in electrical engineering from Polytechnique Montréal (affiliated with Université de Montréal), Canada in 2009. He worked as a Project Engineer at Aselsan Electronics Inc. (1998–2004) and as an R&D Engineer at CYME International T&D (2009–2011). He joined the faculty at Polytechnique Montreal in 2011. Ilhan's career highlights include contributions to professional tools and development of models and solver prototypes for power systems analysis from steady state to electromagnetic transients. He has performed many grid-consulting projects that cover design, modeling, analysis and validation of field measurements. His research is on the development of concepts, models and methods for power systems analysis and massive integration of renewables.

Handy FORTIN-BLANCHETTE received the B.Eng., M.Eng., and Ph.D. degrees in electrical engineering from the École de Technologie Supérieure (ÉTS), Montreal, Canada, in 2001, 2003, and 2010, respectively. From 1994 to 1997, he was engaged in industrial automation. From 1998 to 2000, he was with the Bombardier Transport-ETS Research Laboratory, Montreal, where he worked on a



high power traction system. From 2001 to 2003, he was involved in the development of an electrical drive library for the Simulink (MATLAB) environment. From 2007 to 2010, he was with OPAL-RT Technologies, where he led CPU-based and FPGA-based power electronics real-time simulation projects. From 2010 to 2011, he was a Visiting Scholar at Center for Power Electronic and System, Virginia Polytechnic Institute and State University, Blacksburg, where he was involved in the packaging of high temperature converters for aircraft applications. He is presently an associate professor of Electrical Engineering at the École de Technologie Supérieure. His current research interests include EMI prediction, circuit modeling, and high density power converters packaging.

Carl LAVERTU received the B.Eng. degree in electrical engineering from the Université du Québec à Trois-Rivières, Trois-Rivières, Canada, in 1985. From 1985 to 1991, he was with Lauzon Lavertu Consultants, Inc., Drummondville, Canada. Since 1991, he is with Bombardier Transportation, St.-Bruno, where he is currently a Senior Expert in Power Electronics. He has been working on various rail projects being mainly involved in the design, fabrication, and testing of traction and auxiliary power converters, battery systems, door controllers, and lighting systems. He has two U.S. Patents. He is a Registered Professional Engineer in the province of Québec.